

LEVEL I CERTIFICATES OF APPROPRIATENESS

Historic Zoning Commission Meeting: February 4, 2016

FILE NO.	PROPERTY ADDRESS	DISTRICT	WORK DESCRIPTION
2-A-16-HZ	1127 Luttrell St	Fourth and Gill H-1	Install stain-grade wood full-view double-leafed door totaling 6 feet wide into existing noncontributing rear addition where a door opening previously located. As per submitted specifications.
1-E-16-HZ	12 Market Square	Market Square H-1	Level I Install patio railing as indicated on submitted drawings dated 12/29/16. Install 5.94 SF blade sign at the southeast corner of the second level at 12 Market Square. Paint non-historic brick and EIFS on lower facades of 12 and 14 Market Square respectively.
1-A-16-HZ	601 W Summit Hill Dr	Old City Hall H-1	Replace existing rotted and damaged balcony balustrade elements in-kind. Reinforce balconies on each side of building with 8'x4' steel beams installed underneath existing wood beams perpendicular to the building at 8-foot intervals (not visible on building exterior).