

# Level I Certificates of Appropriateness

Historic Zoning Commission Meeting: January 21, 2021

FILE NO.	PROPERTY ADDRESS	DISTRICT	WORK DESCRIPTION
1-A-21-HZ	2108 Jefferson Ave. / Parcel ID 82 O A 015	Edgewood-Park City H	Repair to existing wood clapboard siding, including replacement in-kind in patches, using siding to match in size, design and placement. Repair to stuccoed masonry foundation. All other scopes of work to be reviewed at 1/21/2021 HZC meeting.
1-B-21-HZ	700 E. Scott Ave. / Parcel ID 81 L C 005	Old North Knoxville H	Masonry repair and repointing to existing west elevation chimney. All repointing will adhere to NPS Preservation Brief 2, using type O mortar appropriate for historic bricks. All loose/fallen bricks will be repaired and replaced in situ. If bricks require replacement, replacement bricks will match existing as closely as possible.